

OPTIONAL ANNUAL REPORT TEMPLATE

Drinking-Water System Number:	260039559
Drinking-Water System Name:	Fanshawe Conservation Area Distribution System
Drinking-Water System Owner:	Upper Thames River Conservation Authority
Drinking-Water System Category:	Non Municipal Year Round Residential
Period being reported:	January 1, 2007 – December 31, 2007

Complete if your Category is Large Municipal Residential or Small Municipal Residential

Does your Drinking-Water System serve more than 10,000 people? Yes [] No []

Is your annual report available to the public at no charge on a web site on the Internet? Yes [] No []

Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.

Complete for all other Categories.

Number of Designated Facilities served:

none

Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No [] not applicable [x]

Number of Interested Authorities you report to:

n/a

Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No [] not applicable [x]

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
n/a	n/a

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes [] No [] not applicable [x]

Drinking-Water Systems Regulation O. Reg. 170/03

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method _____

Describe your Drinking-Water System

The drinking water system consists of a connection to the municipal water supply system in the City of London at Clarke Side Road. The system services the south end of the park consisting of the gatehouse, Administration Office, and Rowing Club. The tenant house that the system once served became vacant in August of 2007 and the water systems were disconnected. The watermain then crosses Fanshawe Dam, where it enters a rechlorination facility located within the workshop compound of Fanshawe Conservation Area. In this facility, the water is injected with sodium hypochlorite which acts as secondary disinfection and ensures a free chlorine residual within the distribution system. From the rechlorination facility, the system supplies water to workshop area, entire campground facility, Pioneer Village and Beach Pavilion. Although there is continuous monitoring in the rechlorination facility, staff also perform daily tests through the distribution system.

List all water treatment chemicals used over this reporting period

Sodium hypochlorite

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment
- None

Please provide a brief description and a breakdown of monetary expenses incurred

No major costs were incurred during this reporting period.

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
None					

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	n/a	n/a	n/a	n/a	n/a
Treated	27	0	0	27	<10 – 20
Distribution	143	0	0	143	<10 - 30

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	n/a	0
Chlorine	407	0.16 – 2.58
Fluoride (If the DWS provides fluoridation)	n/a	0

NOTE: For continuous monitors use 8760 as the number of samples.

*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument. - None Required

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Not required			
Arsenic	Not required			
Barium	Not required			
Boron	Not required			
Cadmium	Not required			
Chromium	Not required			
Lead	Sept 7 -07 Sept 7 -07	ND ND	ug/l	No
Mercury	Not required			

Selenium	Not required			
Sodium	Not required			
Uranium	Not required			
Fluoride	Not required			
Nitrite	Not required			
Nitrate	Not required			

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Not required			
Aldicarb	Not required			
Aldrin + Dieldrin	Not required			
Atrazine + N-dealkylated metabolites	Not required			
Azinphos-methyl	Not required			
Bendiocarb	Not required			
Benzene	Not required			
Benzo(a)pyrene	Not required			
Bromoxynil	Not required			
Carbaryl	Not required			
Carbofuran	Not required			
Carbon Tetrachloride	Not required			
Chlordane (Total)	Not required			
Chlorpyrifos	Not required			
Cyanazine	Not required			
Diazinon	Not required			
Dicamba	Not required			
1,2-Dichlorobenzene	Not required			
1,4-Dichlorobenzene	Not required			
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Not required			
1,2-Dichloroethane	Not required			
1,1-Dichloroethylene (vinylidene chloride)	Not required			
Dichloromethane	Not required			
2,4 Dichlorophenol	Not required			
2,4-Dichlorophenoxy acetic acid (2,4-D)	Not required			
Diclofop-methyl	Not required			
Dimethoate	Not required			
Dinoseb	Not required			
Diquat	Not required			
Diuron	Not required			
Glyphosate	Not required			
Heptachlor + Heptachlor Epoxide	Not required			

Drinking-Water Systems Regulation O. Reg. 170/03

Lindane (Total)	Not required			
Malathion	Not required			
Methoxychlor	Not required			
Metolachlor	Not required			
Metribuzin	Not required			
Monochlorobenzene	Not required			
Paraquat	Not required			
Parathion	Not required			
Pentachlorophenol	Not required			
Phorate	Not required			
Picloram	Not required			
Polychlorinated Biphenyls(PCB)	Not required			
Prometryne	Not required			
Simazine	Not required			
THM (NOTE: show latest annual average)	Feb 26 -07 June 04 -07 Sept 07 -07 Dec 03 -07	18.2	ug/l	No
Temephos	Not required			
Terbufos	Not required			
Tetrachloroethylene	Not required			
2,3,4,6-Tetrachlorophenol	Not required			
Triallate	Not required			
Trichloroethylene	Not required			
2,4,6-Trichlorophenol	Not required			
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Not required			
Trifluralin	Not required			
Vinyl Chloride	Not required			

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards. - *Not Applicable*

Parameter	Result Value	Unit of Measure	Date of Sample